

Console Furniture NCPA-Sunrise #AS-2403 RFI Submittal and Response Log

NCPA RFI#	Author	Date Submitted	Reference	Submittal Question	Response	Response Date
001	Tresco	9/23/2024	App. E	Please provide a copy of Appendix E.	See the attached that includes Appendix E "Sample Agreement"	9/24/2024
002	Tresco	9/23/2024	3.b	Please confirm the number of ports needed for each power, voice and data per operator.	SURFACE Multi-Ports to include the following: (2) USB Passive, (2) 110v Power.	9/24/2024
003	Tresco	9/23/2024	3.d	Can you confirm the monitor size(s) and desired monitor layout per operator?	Monitor configuration per CONSOLE is a total of (12) 24" typical monitors to be configured (6) across and (2) up.	9/24/2024
004	Tresco	9/23/2024	3.e	Can you confirm quantity of phone and speakers per operator position?	Configure each OPERATOR position with the placement and mounting for (2) phones, (1) radio, (1) speaker.	9/24/2024
005	Tresco	9/23/2024	3.k	Please confirm if our understanding of the scope of work is correct. 1.) Tear down and disposal of existing consoles at: 7664 Old Aburn Rd, Citrus Heights, CA 2.)Manufacturing and installation of new consoles at: 5034 Sunrise Blvd, Fair Oaks, CA	Confirmed	9/24/2024
006	Tresco	9/23/2024	Other	Please send as-built drawings and/or pictures of the existing workstations that we are responsible for demolishing.	See attached drawing of three existing workstations for disposal. Dumpsters will NOT be available. Contractor is responsible for haul-away and proper disposal.	9/24/2024
007	Tresco	9/23/2024	Other	Will there be dumpsters available on site for the disposal of the existing consoles	The project is expected to be completed by March 30 th 2025. The awarded bidder will need to provide a project schedule to be coordinated with the General Contractor and NCPA for installation.	9/24/2024
008	Evans	9/27/2024	3c	The proposal must include a layout for six consoles, each with three workstations; for a total of eighteen workstations and twelve staff positions. Can you please clarify "three workstations" and "twelve staff positions"?	total of 6 sit/stand consoles to be used by 12 employees. "Workstations" referring to the number of PC's in total.	9/30/2024
009	Evans	9/27/2024	other	Do you have a AutoCad file of the room these consoles are going into	Yes, NCPA will provide a .DWG file of pg 12 Exhibit C "Floor Plan-New" upon request from bidder.	9/30/2024
010	Evans	9/27/2024	other	Should the map table be standing height	Approximatly 36 Wx70 L x 30H	

Console Furniture NCPA-Sunrise #AS-2403 RFI Submittal and Response Log

NCPA RFI#	Author	Date Submitted	Reference	Submittal Question	Response	Response Date
011	Evans	9/27/2024	other	Can you provide the sizes and/or models of the CPU's being stored at the console?	Typical workstations include the following: Precision 3680 Tower Workstation 14.5(h)x6.8(w)x16.54(d) Precision 3460 Small Form Factor 11.5(h)x3.65(w)x11.5(d)	10/1/2024
012	Evans	9/27/2024	other	Has any consideration been given to storing the CPU's at a remote location?	The Agency has no plans for remote CPU's	10/1/2024